

**Annual Drinking Water Quality Report for 2021**  
**Town of Champlain**  
**729 Route 9, Champlain, NY 12919**  
**Town Public Water Supply ID# NY0930006**

**INTRODUCTION**

To comply with State regulations, we will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. This report provides an overview of last year’s water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact our Water Operator, Chris Matott at (518) 298-8160. We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled board meetings. The Town Board meetings are held the second Tuesday of each month or contact the Clinton County Health Department at (518) 565-4870.

**WHERE DOES OUR WATER COME FROM?**

We purchase our water from the Village of Champlain, please see the Village 2021 Reports for information on the water source and additional sampling. The Ridge Road sub-district has a booster station for boosting pressure and is where the water is re-chlorinated if needed.

**FACTS AND FIGURES**

The Town water system serves a population of approximately 500 persons within the Town. There are approximately 170 service connections within the system. The US Border Crossing, NCCS School, and several commercial businesses are also served.

**ARE THERE CONTAMINANTS IN OUR DRINKING WATER?**

In addition to the sampling conducted by the Village of Champlain, we test your water for lead and copper, disinfection by-products, and total coliform bacteria. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA’s Safe Drinking Water Hotline (800) 426-4791 or Clinton County Health Department at (518) 565-4870.

**Table of Detected Contaminants**

Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg/Max) Range	Unit Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination
Copper <sup>(1)</sup>	No*	09/20/21	90 <sup>th</sup> = 0.97 Range: 0.025 – 1.2	mg/l	1.3	AL = 1.3	Corrosion of household plumbing systems
Lead <sup>(2)</sup>	No*	09/20/21	90 <sup>th</sup> = 1.3 Range: < 1 – 1.3	ug/l	N/A	AL = 15	Corrosion of household plumbing systems
Total Trihalomethanes (TTHM's) <sup>(3)</sup> Location: Castine Rd.	No	09/13/21	43.8	ug/l	N/A	MCL = 80	By-product of drinking water chlorination needed to kill harmful organisms'

**Notes:**

1 - The level presented represents the 90th percentile of 5 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected at your water system. In this case, 5 samples were collected and the 90th percentile value was the first and second highest sample average. The action level for copper was not exceeded at any of the sites tested.

2 - The level presented represents the 90th percentile of 5 sites tested. The action level for lead was not exceeded at any of the sites tested.  
3- Sampling for total trihalomethanes and haloacetic acids (disinfection by-products) is conducted separately for the Town and Village water districts. Trihalomethanes and haloacetic acids are collected at one location. Please see additional health affects language contained within this document.

**Definitions:**

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Milligrams per liter (mg/l):** Corresponds to one part of liquid in one million parts of liquid.

**Micrograms per liter (ug/l):** Corresponds to one part liquid in one billion parts of liquid (parts per billion-ppb).

**WHAT DOES THIS INFORMATION MEAN?**

As you can see by the table, our system had no MCL violations. We have learned through our testing that some contaminants have been detected, however, these contaminants were detected below the level allowed by the State.

If present, elevated level of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. The Town of Champlain Water District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 3 seconds to 2 minutes before using water for drinking and cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

**IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?**

New York State Sanitary Code requires that microbiological samples be collected from our distribution system each month and be analyzed for Total Coliform Bacteria. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other potentially harmful bacteria may be present. We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. No violations were issued during the year of 2021, as our system was in full compliance with all state monitoring and regulatory requirements.

**DO I NEED TO TAKE SPECIAL PRECAUTIONS?**

Some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline at (800-426-4791).

**CLOSING:**

We ask that all our customers help us protect our water sources, which are the heart of our community. If you have any questions regarding the information presented in this report, please do not hesitate to contact us at (518) 298-8160.

Sincerely,

Chris Matott

***Annual Drinking Water Quality Report for 2021***  
***Village and Town of Champlain***  
***11104 Route 9, Champlain, NY 12919***  
***Village Public Water Supply ID# NY0900211***

**INTRODUCTION**

To comply with State regulations we annually issue a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards. If you have any questions about this report or concerning your drinking water, please contact our Water Operator, Woodrow Kissel at (518) 298-4152. We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled board meetings or contact the Clinton County Health Department. The Village Board meets on the second Monday night of each month at 6:30 p.m. at the Village offices and The Town Board meetings are held the second Tuesday of each month.

**WHERE DOES OUR WATER COME FROM?**

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Departments and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our drinking water source is drawn from three deep wells. The wells are 100' deep with 8" casings. Two wells are used as primary sources and the other is used as a back-up source. The Village has studied source water for possible susceptibility to contamination. Please see the Source Water Assessment Program (SWAP) Summary provided by the State Health Department included in this report for additional information. The well water is disinfected with chlorine prior to distribution. Since 1992, the Village has also added orthophosphate for corrosion control, and to prevent rusty water problems.

**FACTS AND FIGURES**

Our water system serves a population of approximately 2,950 persons within the Village, including the NCCS School and the Champlain Border facilities. The water system has approximately 490 connections in the Village of Champlain and 160 connections in the Town of Champlain. The total amount of water produced in 2021 was about 41 million gallons.

**ARE THERE CONTAMINANTS IN OUR DRINKING WATER?**

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, asbestos, gross alpha particle activity, nitrate, lead and copper, haloacetic acids, primary inorganic compounds, total trihalomethanes, and synthetic organic compounds, principal organic chemicals, Radium 226 and Radium 228. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old. It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800) 426-4791 or Clinton County Health Department at (518) 565-4870.

Table of Detected Contaminants							
	Violation	Date of	Level Detected (Avg/Max)	Unit	Detected	Regulatory Limit	Likely Source of Contamination
Contaminant	Yes/No	Sample	Range	Measurement	MCLG	(MCL, TT or AL)	
Copper (1) (Village)	No	09/13/21 – 09/15/21	90 <sup>th</sup> = 1.0 Range: 0.15 - 1.6	mg/l	1.3	AL=1.3	Corrosion of household plumbing, erosion of natural deposits
Lead (1) (Village)	No	09/13/2021– 09/15/21	90 <sup>th</sup> = 1.0 Range: <1.0-1.5	ug/l	0	AL = 15	Corrosion of household plumbing, erosion of natural deposits
Methyl tert-butyl ether MTBE– *Drilled Well #1	No	10/19/17	1.8	ug/l	N/A	100	Leaking fuel storage tanks
Barium – *Drilled Well #1	No	10/19/17	0.11	mg/l	2	MCL=2	Discharge from drilling, waste, erosion of natural deposits
Chromium – *Drilled Well #1	No	10/19/17	6.3	ug/l	100	100	Naturally occurring, can cause allergic dermatitis
Fluoride – *Drilled Well #1	No	10/19/17	0.13	mg/l	N/A	2.2	Naturally occurring
Gross Alpha	No	12/19/18	1.39	pCi/l	N/A	MCL=15	Erosion of natural deposits
Disinfection By-products (2)							
TTHM (Hydrant 43)	No	07/21/21	22.5	ug/l	80	MCL=80	By-product of drinking water Disinfection
TTHM (1104 Main Rt.9)	No	07/21/21	11.4	ug/l	80	MCL=80	
Disinfection By-products (2)							
HAA5 (Hydrant 43)	No	7/21/21	4.8	ug/l	60	MCL=60	By-product of drinking water disinfection
HAA5 (1104 Main Rt.9)	No	7/21/21	3.4	ug/l	60	MCL=60	
Dibromochloromethane (POC's)	No	10/12/21	0.6	ug/l	N/A	80	By-product of drinking water disinfection

**Notes:**

\* - Drilled well # 1 was dormant for a period of time and was tested in 2017 in order to be put online.

1- Sampling for lead and copper is conducted separately for the Town and Village water districts. The level presented represents the 90th percentile of the 10 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the lead/copper values detected at your water system. In this case, 10 samples were collected at your water system and the 90th percentile value was the 2<sup>nd</sup> highest value. The action level for lead was not exceeded at any testing sites and the action level for copper was exceeded at 1 testing site.

2- Sampling for total trihalomethanes and haloacetic acids (disinfection by-products) is conducted separately for the Town and Village water districts.

**Definitions:**

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

**Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Treatment Technique (TT):** Required process intended to reduce level of a contaminant in drinking water.

**Non-Detects (ND):** Laboratory analysis indicates that the constituent is not present.

**Milligrams per liter (mg/l):** Corresponds to one part of liquid in one million parts of liquid.

**Micrograms per liter (ug/l):** Corresponds to one part liquid in one billion parts of liquid (parts per billion-ppb).

**Picocuries per liter (pCi/L):** A measure of the radioactivity in water.

**BRL:** Below reportable limits

## **WHAT DOES THIS INFORMATION MEAN?**

As you can see by the table we have learned through our testing that some contaminants have been detected; however, these contaminants were detected below the level allowed by the State. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. Village of Champlain Water District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 3 seconds to 2 minutes before using water for drinking and cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

## **IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?**

We are required to monitor your drinking water for specific contaminants on a regular basis. During 2021, our systems were in compliance with applicable State drinking water operating, monitoring and reporting requirements. There were a total of 10 Boil Water Orders (BWO's) on the following dates: 02/17/2021, 03/31/2021, 05/15/2021, 08/04/2021, 10/11/2021, 10/22/2021, 10/27/2021 and 11/09/2021, 11/21/2021, and 12/01/2021. These BWO's were precautionary and issued due to water main breaks and subsequent shut downs to make repairs, or system upgrades and routine maintenance. All BWO's were lifted with satisfactory bacteriological check samples.

## **DO I NEED TO TAKE SPECIAL PRECAUTIONS?**

Some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline at (800-426-4791).

## **WHY SAVE WATER AND HOW TO AVOID WASTING IT?**

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- Saving water saves energy and some of the costs associated with both of these necessities of life;
- Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential firefighting needs are met.
- You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:
  - ✓ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
  - ✓ Turn off the tap when brushing your teeth.
  - ✓ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it up and you can save almost 6,000 gallons per year.
  - ✓ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these invisible toilet leaks. Fix it and save more than 30K gallons a year.
  - ✓ Use your water meter to detect hidden leaks. Simply turn off all taps and water using appliances, then check the meter after 15 minutes, if it moved, you have a leak

It is recommended that customers retrofit their plumbing with water saving and conservation devices. Upon request, DPW employees will show customers water leak detection procedures that can be easily instituted in the home.

**Champlain Village - (PWS# NY0900211):**

**Source Water Assessment Program (SWAP) Summary for AWQR**

The NYS DOH has completed a source water assessment for this system, based on available information. Possible and actual threats to this drinking water source were evaluated. The state source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to consumers is, or will become contaminated. See section "Are there contaminants in our drinking water?" for a list of the contaminants that have been detected. The source water assessments provide resource managers with additional information for protecting source waters into the future.

As mentioned before, our water is derived from 3 drilled wells. The source water assessment has rated these wells as having a high susceptibility to enteric bacteria, enteric viruses, herbicides/pesticides, and nitrates. These ratings are due primarily to the close proximity of permitted discharge facilities (industrial/commercial facilities that discharge wastewater into the environment and are regulated by the state and/or federal government), and residential properties within the assessment area. The source water assessment has also rated these wells as having a medium-high susceptibility to halogenated solvents, metals, nitrates, industrial organics, petroleum products, and protozoa. These ratings are given because the wells are located in an area that may be prone to flooding. Please note that, while the source water assessment rates our wells as being susceptible to microbials, our water is disinfected to ensure that the finished water delivered into your home meets the New York State drinking water standards for microbial contamination. A copy of the assessment, including a map of the assessment area, can be obtained by contacting us, as noted.

**CLOSING:**

We ask that all our customers help us protect our water sources, which are the heart of our community. If you have any questions regarding the information presented in this report, please do not hesitate to contact our Public Works Department at (518) 298-4152.